



GLOUCESTER TOWNSHIP FIRE DISTRICT 4

BUREAU OF FIRE PREVENTION

14 WEST CENTRAL AVENUE
 BLACKWOOD, N.J. 08012
 856-227-7731 / FAX 856-227-2494
 www.gtfd4.org

SMOKE DETECTOR, CARBON MONOXIDE DETECTOR AND FIRE EXTINGUISHER CERTIFICATION APPLICATION

<p>Owner Information:</p> <p>Owner Name: _____</p> <p>Property Address: _____ _____</p> <p>Phone: _____</p> <p>Block: _____ Lot: _____</p> <p>Property Status: <input type="checkbox"/> Occupied <input type="checkbox"/> Vacant</p>	<p>Realtor Information:</p> <p>Realtor Name: _____</p> <p>Realtor Address: _____ _____</p> <p>Realtor: _____</p> <p>Phone: _____</p> <p>Settlement Date: _____</p> <p>Key Box: <input type="checkbox"/> Yes <input type="checkbox"/> No Code: _____</p>
--	---

Inspection Checklist

- Numbers are numerical characters, contrasting color from the house, at least 4" high, permanently affixed to the house & visible from the street. *Light post or mailbox numbers are NOT acceptable.*

Smoke Alarms *** Battery detectors **MUST** be Ten-year sealed battery detectors*** (A/C powered detectors are exempt)

- Smoke alarm located on **every level** of dwelling.
- Basement level alarm is located at bottom of stairwell, at ceiling level (not between joists).
- Bedroom hallway alarms **MUST** be within 10 feet of **ALL** bedrooms doors.
- *Electric smoke alarms (hardwired) **CANNOT** be replaced with battery operated alarms.
- Do **NOT** install smoke alarms in kitchens, bathrooms, near forced air ducts or furnaces, in the "dead air" space where the ceiling meets the wall, close to ceiling fans, in crawl spaces or attics.

Carbon Monoxide Alarms

- Located inside each bedroom or inside the hallway, within 10 feet of **ALL** bedrooms doors.
- Installed per manufacturer's instructions.
- Carbon monoxide alarm(s) are less than 7 years old and are operational.
- Do **NOT** place alarms in electrical outlets that can be turned off by a switch or that are located against floor molding. Plug-in, battery powered and hardwired CO alarms are acceptable.

Fire Extinguisher

- **ABC** type, rated for residential use. **2A-10B:C extinguisher only acceptable**
- Must be dated or tagged for current year. (by approved NJ licensed vendor)
- **MOUNTED** within 10 feet of the kitchen (mounting permissible inside of a cabinet or closet).

OFFICE USE ONLY

Date Received: _____

Payment Method: _____

Check #: _____

Recorded by: _____

Scheduled for: _____

Time: _____

Fees ***BASED ON BUSINESS DAYS***

Applications received 10 or more days prior to settlement.	\$45.00
Applications received 4-9 days prior to settlement.	\$90.00
Applications received less than 4 days prior to settlement.	\$161.00